

BSRIA Certificate

This is to certify that the following Duct Flange joint system has complied with the requirements of The Heating and Ventilating Contractors' Association's test method, TM1, for rating duct flange joints and DW/142 Specification for sheet metal ductwork.

System MEZ-FLANGE-SYSTEM 20

Flange type or number 120 LS

Gauge of material Classes Low A)
Medium B) 0.8 mm
High (C)
(D)


Corner type or number 225

Flange clamp MEZ.505

Joint rating achieved J2

Pressure classes Low A, Medium B, High C and D

Certificate No: 53600/1



Signature of Test Engineer

Date: 18 October 1988

Building Services Research and Information Association

Old Bracknell Lane West, Bracknell, Berkshire, RG12 4AH. Tel: (0344) 426511 Telex: 848288
BSRIAC G Fax: (0344) 487575

A company limited by guarantee registered in England No. 632760.

BSRIA Certificate

This is to certify that the following Duct Flange joint system has complied with the requirements of The Heating and Ventilating Contractors' Association's test method, TM1, for rating duct flange joints and DW/142 Specification for sheet metal ductwork.

System MEZ-FLANGE-SYSTEM 30

Flange type or number 130 LS

Gauge of material Classes Low A) 1 mm
Medium B)
High (C) 0.8 mm
(D)


Corner type or number 233

Flange clamp MEZ.505

Joint rating achieved J3

Pressure classes Low A, Medium B, High C and D

Certificate No: 53600/2


Signature of Test Engineer

Date: 18 October 1988

Building Services Research and Information Association

Old Bracknell Lane West, Bracknell, Berkshire, RG12 4AH. Tel: (0344) 426511 Telex: 848288
BSRIAC G Fax: (0344) 487575

A company limited by guarantee registered in England No. 632760.

BSRIA Certificate

This is to certify that the following Duct Flange joint system has complied with the requirements of The Heating and Ventilating Contractors' Association's test method, TM1, for rating duct flange joints and DW/142 Specification for sheet metal ductwork.

System MEZ-FLANGE-SYSTEM 30

Flange type or number 130 LS

Gauge of material Classes Low A)
Medium B) 1 mm
High (C)
(D)


Corner type or number 233

Flange clamp MEZ.505

Joint rating achieved J4

Pressure classes Low A, Medium B, High C & D

Certificate No: 53600/3



Signature of Test Engineer

Date: 18 October 1988

Building Services Research and Information Association

Old Bracknell Lane West, Bracknell, Berkshire, RG12 4AH. Tel: (0344) 426511 Telex: 848288
BSRIAC G Fax: (0344) 487575

A company limited by guarantee registered in England No. 632760.

BSRIA Certificate

This is to certify that the following Duct Flange joint system has complied with the requirements of The Heating and Ventilating Contractors' Association's test method, TM1, for rating duct flange joints and DW/142 Specification for sheet metal ductwork.

System MEZ-FLANGE-SYSTEM 40

Flange type or number 141 LS

Gauge of material	Classes	Low A)	1.2	mm
		Medium B)	1.0	
		High (C)	1.2	
		(D)	1.0	


Corner type or number 245

Flange clamp MEZ.505

Joint rating achieved J5

Pressure classes Low A, Medium B, High C and D

Certificate No: 53600/4



Signature of Test Engineer

Date: 18 October 1988

Building Services Research and Information Association

Old Bracknell Lane West, Bracknell, Berkshire, RG12 4AH. Tel: (0344) 426511 Telex: 848288
BSRIAC G Fax: (0344) 487575

A company limited by guarantee registered in England No. 632760.

BSRIA Certificate

This is to certify that the following Duct Flange joint system has complied with the requirements of The Heating and Ventilating Contractors' Association's test method, TM1, for rating duct flange joints and DW/142 Specification for sheet metal ductwork.

System MEZ-FLANGE-SYSTEM 40

Flange type or number 141 LS

Gauge of material Classes Low A)
Medium B) 1.2 mm
High (C)
(D)


Corner type or number 245

Flange clamp MEZ.505

Joint rating achieved J6

Pressure classes Low A, Medium B, High C and D

Certificate No: 53600/5



Signature of Test Engineer

Date: 18 October 1988

Building Services Research and Information Association

Old Bracknell Lane West, Bracknell, Berkshire, RG12 4AH. Tel: (0344) 426511 Telex: 848288
BSRIAC G Fax: (0344) 487575

A company limited by guarantee registered in England No. 632760.